



OFFICE OF THE STATE FIRE MARSHAL



JANICE BREWER
GOVERNOR

GENE PALMA
DIRECTOR

ROBERT BARGER
FIRE MARSHAL

1110 WEST WASHINGTON, SUITE 100
PHOENIX, ARIZONA 85007
Phone: (602) 364-1003
Fax: (602) 364-1052
Inspection line: (602) 364-1085

**Inspection Requirements for a General construction Final.
The referenced requirements are contained in the 2003 IFC fire codes.**

- Arizona State Fire Marshal approved plans and permit on site.
- Appropriate General contractor on site.
- Fire Lanes are accessible and marked appropriately.
- Fire lanes meet the requirements of the 2003 IFC 503.2.1.
- Building addresses correctly sized and readable Facing Street per 2003 IFC 505.1.
- All required fire protection systems are installed and approved.
- All fire protection water supplies installed and approved.
- Fire hydrants installed and located for fire department response.
- All emergency exits available for use.
- All exit signs illuminated and tested on backup power.
- Emergency lighting tested on primary and backup power.
- Required panic hardware installed and tested.
- All special systems installed have final approval.
- Fire department lock box (if required) by local jurisdiction.
- **General contractor to call for Final when ready.**
- **This form is used only as a guide. Final approval is contingent upon favorable field inspection.**